

Consumer Confidence Report

Annual Drinking Water Quality Report

CHATSWORTH

IL1050100

Annual Water Quality Report for the period of January 1 to December 31, 2023

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by CHATSWORTH is Ground Water

For more information regarding this report contact:

Name Ben Mogged

Phone (818) 635-3095

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

Source of Drinking Water
<p>The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.</p> <p>Contaminants that may be present in source water include:</p> <ul style="list-style-type: none"> Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming. Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses. Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems. Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. EPA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Source Water Information

Source Water Name	Type of Water	Report Status	Location
WELL 1 (WL47500) WEST WELL	GW	<u>Active</u>	<u>S of Maple St</u>
WELL 2 (WL47501) SPRUCE AND 3RD	GW	<u>Active</u>	<u>NW of Spruce</u>
WELL 3 (WL47502) S WELL OF COUNTRY COUNTRY WELL	GW	<u>Active</u>	<u>S well of Canada Hill</u>
WELL 4 (WL47503) N WELL OF COUNTRY	GW	<u>Active</u>	NORTH OF TWO WELLS NORTH OF TOWN

Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at **(815) 635-3095**. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Source of Water: CHATSWORTH To determine Chatsworth's susceptibility to groundwater contamination, a Well Site Survey, published in 1989 by the Illinois EPA, and Source Water Protection Plan were reviewed. Based on the information obtained in these documents, 25 potential sources of groundwater contamination are present that could pose a hazard to groundwater pumped by the Chatsworth community water supply wells. These include two mines other than sand, gravel, or stone; two manufacturing processes; three below ground fuel storages; four above ground storages; three grain elevators; four machine shops/sheds; a treated wood/lumber yard; three waste piles; a vehicle sales; a warehouse; and an auto repair. Based upon this information, the Illinois EPA has determined that Chatsworth Wells #1, #2, #3, and #4 are not susceptible to IOC, VOC, or SOC contamination. This determination is based on a number of criteria including: monitoring conducted at the wells; monitoring conducted at the entry point to the distribution system; and the available hydrogeologic data for the wells. In anticipation of the U.S. EPA's proposed Ground Water Rule, the Illinois EPA has determined that Chatsworth's community water supply wells are not vulnerable to viral contamination. This determination is based upon the evaluation of the following criteria during the Vulnerability Waiver Process: the community's wells are properly constructed with sound integrity and proper site conditions; there is a hydrogeologic barrier that restricts pathogen movement; all potential routes and sanitary defects have been mitigated such that the source water is adequately protected; monitoring data did not indicate a history of disease outbreak; and the sanitary survey of the water supply did not indicate a viral contamination threat. However, having stated this, the U.S. EPA is proposing to require States to identify systems in karst, gravel and fractured rock aquifer systems as sensitive. Water systems utilizing these aquifer types would be required to perform routine source water monitoring. Because the community's wells are constructed in a confined aquifer, which should provide an adequate degree of protection to prevent the movement of pathogens into the wells, well hydraulics were not considered to be a significant factor in the vulnerability determination.

2023 Regulated Contaminants Detected

Lead and Copper

Definitions:
Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	09/28/2021	1.3	1.3	0.7	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.

Water Quality Test Results

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

na: not applicable.

mrem: millirems per year (a measure of radiation absorbed by the body)

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Chlorine	Haloacetic Acids (HAAs)	Total Trihalomethanes (TTHM)	Inorganic Contaminants	Arsenic	Barium	Fluoride	Manganese	Nitrate [measured as Nitrogen]	Nitrite [measured as Nitrogen]	Sodium
Collection Date	Collection Date	Collection Date	Collection Date	Collection Date	Collection Date	Collection Date	Collection Date	Collection Date	Collection Date	Collection Date	Collection Date
Highest Level Detected	Highest Level Detected	Highest Level Detected	Highest Level Detected	Highest Level Detected	Highest Level Detected	Highest Level Detected	Highest Level Detected	Highest Level Detected	Highest Level Detected	Highest Level Detected	Highest Level Detected
Range of Levels Detected	Range of Levels Detected	Range of Levels Detected	Range of Levels Detected	Range of Levels Detected	Range of Levels Detected	Range of Levels Detected	Range of Levels Detected	Range of Levels Detected	Range of Levels Detected	Range of Levels Detected	Range of Levels Detected
MCLG	MCLG	MCLG	MCLG	MCLG	MCLG	MCLG	MCLG	MCLG	MCLG	MCLG	MCLG
MCL	MCL	MCL	MCL	MCL	MCL	MCL	MCL	MCL	MCL	MCL	MCL
Units	Units	Units	Units	Units	Units	Units	Units	Units	Units	Units	Units
Violation	Violation	Violation	Violation	Violation	Violation	Violation	Violation	Violation	Violation	Violation	Violation
Likely Source of Contamination	Likely Source of Contamination	Likely Source of Contamination	Likely Source of Contamination	Likely Source of Contamination	Likely Source of Contamination	Likely Source of Contamination	Likely Source of Contamination	Likely Source of Contamination	Likely Source of Contamination	Likely Source of Contamination	Likely Source of Contamination
	1.4	8	8	0.76	0.76	0.0391	0.77	26.5	2	0.26	67500
	0.5 - 3.09	7.8 - 7.8	7.5 - 7.5	0.76 - 0.76	0.76 - 0.76	0.0391 - 0.0391	0.77 - 0.77	26.5 - 26.5	1.9 - 2.16	0.26 - 0.26	67500 - 67500
	MRDLG = 4	No goal for the total	No goal for the total	0	0	2	4	150	10	1	1
	MRDL = 4	60	80	10	10	2	4.0	150	10	1	1
	ppm	ppb	ppb	ppb	ppb	ppm	ppm	ppb	ppm	ppm	ppm
	N	N	N	N	N	N	N	N	N	N	N
	Water additive used to control microbes.	By-product of drinking water disinfection.	By-product of drinking water disinfection.	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.	Discharge of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.	This contaminant is not currently regulated by the USEPA. However, the state regulates. Erosion of natural deposits.	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.	Erosion from naturally occurring deposits. Used in water softener regeneration.